

Addendum 1:

Questions:

Q: Is a bid bond required?

A: No

Q: Clarify the allowance

A: The \$15,000 is an allowance so any expenses above that the College will be responsible for but the College will only pay for what was expensed with markup. Backup must be provided to be reimbursed against that allowance.

Q: Does the electrical need to be on its own circuit?

A: No, it can be a local 120v circuit

Owner Notes:

The project must be completed and paid for by April 2022, since we are using federal funds and they expire at this time.

Updated Equipment List/Pricing Sheet: Edits are noted in red below

Building	Equipment	CFM output (max)	Cost
FINDLAY			
Education Center- Findlay	RTU-1	10,000	
	RTU-2	11,000	
	RTU-3	18,000	
Community Education Center- Findlay	RTU-1	16,000	
	RTU-2	10,000	
	RTU-3	3,600	
	RTU-4	3,600	
Childcare Center- Findlay	RTU-1	2,000	
	RTU-2	2,000	
Facility Services Building- Findlay	Furnace -1	1,200	
	Furnace- 2	1,300	
TOLEDO			
Heritage Hall (Culinary)	RTU-1	24,457	
	RTU-2	4,241	
Childcare Center	RTU-1	16,900	
Engineering Technologies	AHU-1	25,500	

	AHU-2	9,770	
	AHU-3	16,030	
Transportation Technologies	RTU-1	10,215	
	RTU-2	12,830	
Dana Center	RTU-1	4,000	
	RTU-2	4,400	
	RTU-3	4,200	
	RTU-4	5,200	
	RTU-5	6,800	
	RTU-6	3,200	
	RTU-7	8,000	
	RTU-8	5,200	
Founders Hall	AC-5	9,000	
	HV-1	30,000	
	HV-2	6,000	
Welding Design Center	RTU-1	525	
	TRANE Mini-Split	300	
	TRANE Mini-Split	300	
Veterans Hall	RTU-1	10,000	
	RTU-2	5,000	
	RTU-3	5,000	
Administration Hall	RTU-1	26,000	
Alumni Hall	AHU-1	41,000	
	ACU-1	170	
	H-1	1575	
	H-2	2140	
	H-3	470	
Law Enforcement Center	AHU-1	41,000	
Center for Emergency Preparedness	RTU-1	4,500	
	RTU-2	4,000	
	RTU-3	4,000	
SHAC	AHU-5	6,300	
	RTU-4	1,045	
	RTU-5	1,280	
	RTU-6	1,280	
	RTU-7	1,155	
	RTU-8	1,515	
\$15,000 electrical allowance included in proposal			\$15,000
Contractor markup on electrical charges			%